



# भारतीय प्रबंध संस्थान इन्दौर

प्रबंध शिखर, राऊ-पीथमपुर रोड, इन्दौर - 453 556 (म.प्र.), भारत

**INDIAN INSTITUTE OF MANAGEMENT INDORE**

Prabandh Shikhar, Rau-Pithampur Road, Indore - 453 556 (M.P.), India

## Answer to queries raised during Pre-bid conference / Clarification of doubts sought by intending tenderers

A pre-bid conference was organized on dated 12.02.2015 at 10.00 A.M. and during the same intending tenderers raised some queries as well as some intending tenderers also sought clarification of doubts on telephone in respect of the NIT advertised vide ref. no. NIT/IIMI/PROJECT/01/2015/13 dated: February 06,2015 with special reference to

- File No.: IIMI/ Project /266/15-Construction of Glass partition work & compartmentalization of space above false ceiling in New Administration building at IIM Indore
- File No.: IIMI/ Project /269/15-Construction of Modular Kitchen in Faculty residence, Visiting Faculty residence and Type-V quarters at IIM Indore
- File No.: IIMI/ Project /270/15-Construction, supply & installation of Modular Furniture/Fixture for Faculty Residence, Visiting Faculty Residence & IPM Hostels at IIM Indore

Though the queries have been answered / doubts have been clarified on spot but the collation of the same has also been done and the same is hereby provided for kind reference to other / those intending tenderers who have not participated due to any reason.

- |       |               |  |
|-------|---------------|--|
| (i)   | Query         | : Clear space between the double glazing of 5mm each in Glass partition.   |
|       | Clarification | : Minimum Clear space between the double glazing of 5mm Glass partition will be 60mm.  |
| (ii)  | Query         | : Whether Aluminum section rate will be inclusive of the anodizing /powder coating and if so, pl. provide the specification .  |
|       | Clarification | : Yes, it should be inclusive of the epoxy/polyester powder coating and the respective specification is available in the tender doc. Vol-II at page no.137-138.  |
| (iii) | Query         | : Whether joint venture is permitted.  |
|       | Clarification | : Yes, the details are there in length in the tender doc. Vol-I .  |
| (iv)  | Query         | : What is the eligibility criteria.  |
|       | Clarification | : Please refer vol-I'A' & vol-I-'B' where it has been discussed in length.   |
| (v)   | Query         | : Is it mandatory to provide documentary evidence of Govt. work of value 40% along with the other criteria laid down in clause 3.14.1-c(i).  |
|       | Clarification | : yes, the intending tendered has to produce evidence of One completed work of any nature (either part of c-(i) or a separate one) costing not less than the amount equal to 40% of the estimated cost put to tender with some Central Government Department / State Government Department / Central Autonomous Body/ State Autonomous Body/ Central Public Sector Undertaking/ State Public Sector Undertaking /City Development Authority / Municipal Corporation of City formed under any Act by Central/ State Government and published in Central /State Gazette. |
| (vi)  | Query         | : The drawing in furniture tender doc. Is missing.   |
|       | Clarification | : Yes, the respective pages is blank in the main tender doc. Due to some technical problem occurred during conversion in pdf. Format. But the same pages have already been uploaded beside the main link of tender of furniture at IIM website & in corrigendum at CPP.  |
| (vii) | Query         | : Whether the time allowed for completion of job can be extended.  |
|       | Clarification | : No, it will be governed by the tender doc.   |

